

**SECTION 00 91 13
ADDENDA**

MT. GILEAD WATER CONSERVATION PROJECT

Addendum No. 1
Date: 06/13/24

Prepared by:

Prunuske Chatham, Inc. (PCI)
103 Morris St. Suite A-5
Sebastopol, CA 95472

Prepared for:

Gold Ridge RCD
2776 Sullivan Rd.
Sebastopol, CA 95472

To: Prospective Bidders:

This addendum forms part of the "Bid Documents." Prospective Bid Proposers shall acknowledge receipt of the total number of the Addenda issued for this project on the space provided in Section 00 41 00 Bid Form. Failure to do so may subject Bid Proposers to disqualification.

The following questions/answers, clarifications, and changes are applicable to the project referenced above.

ADDENDUM NO. 1:

I. Changes

The following items are changes or additions to the Project Documents.

- A. Technical Specification Irrigation 32 80 00 has been changed to clarify that:
- a. For all ball valves sized 4" and under, use SCH 80 True Union Ball valve, Socket connection.
 - b. For all 2" brass gate valves, use 2" Cast Iron Butterfly Valve Wafer - EPDM Seat, Lever Operated with Stem extensions as needed to have handle approximately 2' above finish grade. Use 2" SCH 80 PVC Van Stone Flanges, Slip, to connect to PVC.

END OF SECTION 00 91 13